

SECTION 23 31 00

RECTANGULAR, FACTORY BUILT, FIRE-RESISTANT GREASE DUCT

PART 1 – GENERAL

1.1 SUMMARY

Factory built, single wall rectangular grease duct, listed for fire-resistance and 18" to combustibles. Model GRS factory built grease ducts are intended to be part of a complete grease duct system which connects the hood or grease extractor with the outdoors by means of an exhaustor or blower system.

1.2 REFERENCE STANDARDS

- A. The latest published edition of a standard shall be applicable to this project unless identified by a specific edition date.
- B. All materials and installation shall comply with the applicable requirements and standards.
 - 1. Underwriters Laboratories, Inc. (UL):
 - a. Provide products which have been listed and labeled to the following UL standards:
 - 1. UL 1978/ ULC S662 – *Standard for Grease Ducts*
 - 2. National Fire Protection Association (NFPA):
 - a. Comply with NFPA 96 – *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*
 - 3. International Code Congress (ICC)
 - a. When applicable to the project site, comply with:
 - 1. *International Mechanical Code*
 - 2. *International Building Code*
 - 4. International Association of Plumbing and Mechanical Officials (IAPMO):
 - a. When applicable to the project site, comply with:
 - 1. *Uniform Mechanical Code*

1.3 QUALITY ASSURANCE

- A. Obtain listed system components from a single manufacturer.
- B. Comply with NFPA 96, unless otherwise indicated, or comply with local authority having jurisdiction.
- C. Grease duct system shall be installed in accordance with the manufacturer's listings and written instructions.

1.4 WARRANTY

- A. Listed grease duct shall have a limited 1 year warranty starting at the date of installation.

PART 2 – PRODUCTS

2.1 AVAILABLE MANUFACTURERS

- A. Listed Single Wall insulated rectangular grease duct shall be Model GRS, as manufactured by the Van-Packer Co.

2.2 LISTED GREASE DUCT

- A. The grease duct shall be insulated, single-wall factory built type for use with Type I kitchen hoods, as described in NFPA 96, for the transportation of grease laden vapors from commercial cooking operations.
- B. Product Description:
 - a. Model GRS Rectangular Grease Duct by Van-Packer Co.
 - b. Continuous operation at 18 inch clearance to combustibles.
 - c. Factory built, single-wall type, listed and labeled to UL 1978 for the venting of grease laden vapors from type 1 kitchen hoods requiring grease duct as described in NFPA 96.
 - d. Continuous operating temperatures are 500° F (260° C) or less and for intermittent temperatures not exceeding 2000° F (1093° C).
 - e. All components of the grease duct system, including duct supports, guides, fittings, cleanouts, and expansion joints through penetration fire-stops, shall be provided by a single manufacturer to ensure the system meets the requirements of the UL1978 listing.
 - f. GRS grease ducts should be installed at a slope not less than 1/8 unit vertical in 12 units horizontal toward the hood or toward a grease reservoir. Where horizontal ducts exceed 75 feet in length, the slope shall be not less than 1/4 unit vertical in 12 units horizontal.
 - g. Listed access doors shall be provided, spaced, and located in accordance with the requirements of NFPA 96.
 - h. The rectangular grease duct sections shall be constructed of 0.035" thick Type 304 stainless steel.
 - i. Rectangular grease duct in width to height ratios of up to 6:1 ratio with the ability to mix with round grease ducts in a system.
 - j. Maximum duct size under UL listing is 48 inches x 48 inches rectangular, not to exceed a total of 2,304 square inches.

PART 3 – EXECUTION

3.1 INSTALLATION OF FACTORY BUILT GREASE DUCT

- A. Inner liner joints shall be held together by means formed bolted flanges and sealed with P/N 101087A sealant.
- B. Connection to hood will be made with a hood collar provided to hood manufacturers to assure proper fit with duct.
- C. Connection to curb mounted fans shall be by means of a fan adapter plate provided by the duct manufacturer.
- D. Support duct in accordance with Van-Packer's installation instructions.
- E. All supports and guides shall be designed for installation with no required welding.
- F. Store grease duct components inside or covered adequately to protect from weather or accidental damage.
- G. Follow installation instructions and contact local building and fire officials about jurisdiction and installation inspections in your area.